

- 3 a. Replace sloped ramp from parking lot. Provide ADA handrail at ramp. \$ 35,000
- 3 b. Grind / patch concrete sidewalk to create accessible path throughout campus. \$ 25,000
- 4. Fire alarm. w/ health & safety

**Accessibility  
Long Term Solution**

- 5. Provide an elevator for access to 2nd floor of Fine Arts Building. \$ 80,000
- 6. Replace stair handrails in Fine Arts w/ ADA handrail. \$ 40,000
- 7. Provide elevator for access to lower level locker rooms in Field House. \$ 50,000
- 8. Replace exterior stair handrail with ADA compliant handrails. \$ 70,000
- 9. Elevator at Adm Bldg does not meet minimum cab dimensions. redesign req'd
- 10. Band/ Choral and Lecture hall tired seating not accessible. redesign req'd
- 11. Auditorium stage not accessible. Handrails req'd on sloped floor. redesign req'd
- 12. Library ramp and stairs not ADA compliant. redesign req'd